

Certificate

Hygiene – Conformity Test

Tested sample	Components of an Air Handling Unit type "AT" This certificate applies exclusively to the components described in Appendix 1.	
Client / Manufacturer	AL-KO THERM GMBH, Hauptstraße 248 – 250, 89343 Jettingen-Scheppach	
Test date / place	29/05/2024 / 89343 Jettingen-Scheppach	
Test Engineer	Dipl. Ing. (FH) Jacob Kornack, Jägerstr. 19 / HH, 01099 Dresden	
Test criteria	As part of the Hygiene-Conformity Test, the relevant hygiene requirements* of the following regulations were tested:	
	General ventilation and air conditioning	Hospital sector
	VDI 6022 Blatt 1:2018-01	DIN 1946-4:2018-09
	VDI 3803 Blatt 1:2020-05	ÖNORM H 6020:2024-03
	ÖNORM H 6021:2023-01	SWKI VA105-01:2015-08
	SWKI VA104-01:2019-01	
Test result	The conformity of the tested sample with the hygiene-relevant requirements of the above mentioned regulations is confirmed.	
Validity period	6 years: 05/2024 – 05/2030	
Registration number	HKP 05/24 - 01	



Dipl.-Ing. (FH) J. Kornack

Issued on 09/11/2026 Dresden

* Regulations and/or requirements from regulations to which reference is made in the regulations used for this Hygiene - Conformity Test were not considered. The Hygiene - Conformity Test includes no toxicological testing or assessments of the materials used in the tested prototype. This certificate including its appendices may only be distributed, duplicated and/or be made accessible in its entire form.

